

Hyper Heat MULTI INDOOR UNITS COMBINATION RULE

Multi DC Outdoor Unit	Two units		Three units			Four units				Five units				
	Unit 1	Unit 2	Unit 1	Unit 2	Unit 3	Unit 1	Unit 2	Unit 3	Unit 4	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5
Hyper 1 drive 2	9K	9K												
	9K	12K												
	12K	12K												
Hyper 1 drive 3	9K	9K	9K	9K	9K									
	9K	12K	9K	9K	12K									
	9K	18K	9K	9K	18K									
	9K	24K	9K	12K	12K									
	12K	12K	12K	12K	12K									
	12K	18K												
	12K	24K												
Hyper 1 drive 4	18K	18K												
	9K	18K	9K	9K	9K	9K	9K	9K	9K					
	9K	24K	9K	9K	12K	9K	9K	9K	12K					
	9K	30K	9K	9K	18K	9K	9K	9K	18K					
	12K	12K	9K	9K	24K	9K	9K	12K	12K					
	12K	18K	9K	9K	30K	9K	9K	12K	18K					
	12K	24K	9K	12K	12K	9K	12K	12K	12K					
	12K	30K	9K	12K	18K	12K	12K	12K	12K					
	18K	18K	9K	12K	24K									
	18K	24K	9K	18K	18K									
1 drive 5	18K	30K	12K	12K	12K									
	24K	24K	12K	12K	18K									
			12K	12K	24K									
			12K	18K	18K									
	9K	24K	9K	9K	18K	9K	9K	9K	9K	9K	9K	9K	9K	9K
	9K	30K	9K	9K	24K	9K	9K	9K	12K	9K	9K	9K	9K	12K
	9K	36k	9K	9K	30K	9K	9K	9K	18K	9K	9K	9K	9K	18K
	12K	24K	9K	9K	36k	9K	9K	9K	24K	9K	9K	9K	9K	24K
	12K	30K	9K	12K	12K	9K	9K	9K	30K	9K	9K	9K	12K	12K
	12K	36k	9K	12K	18K	9K	9K	9K	36k	9K	9K	9K	12K	18K
	18K	18K	9K	12K	24K	9K	9K	12K	12K	9K	9K	9K	12K	24K
	18K	24K	9K	12K	30K	9K	9K	12K	18K	9K	9K	12K	12K	12K
	18K	30K	9K	12K	36k	9K	9K	12K	24K	9K	9K	12K	12K	18K
	18K	36k	9K	18K	18K	9K	9K	12K	30K	9K	12K	12K	12K	12K
	24K	30K	9K	18K	24K	9K	9K	18K	18K	12K	12K	12K	12K	12K
	24K	36k	9K	18K	30K	9K	9K	18K	24K					
	30K	30K	9K	18K	36k	9K	12K	12K	12K					
			9K	24K	24K	9K	12K	12K	18K					
			9K	24K	30K	9K	12K	12K	24K					
			12K	12K	12K	9K	12K	12K	30K					
		12K	12K	18K	9K	12K	18K	18K						
		12K	12K	24K	9K	12K	18K	24K						
		12K	12K	30K	12K	12K	12K	12K						
		12K	12K	36k	12K	12K	12K	18K						
		12K	18K	18K	12K	12K	12K	24K						
		12K	18K	24K	12K	12K	18K	18K						
		12K	18K	30K										
		12K	24K	24K										
		18K	18K	18K										
		18K	18K	24K										
Note:	If total indoor units load exceeds nominal capacity of outdoor unit, the practical output capacity of each indoor unit will be correspondingly attenuated. This situation is very evidently during heating mode.													
	Rules: Outdoor unit Capacity*0.66<= Indoor unit total capacity <= Outdoor unit Capacity 1.33													