ComfortStar®

Submittal

Split System Cooling

CWM5-18-15R

| Location: |
|---------------|
| Engineer: |
| Submitted to: |
| Submitted by: |
| Reference: |

| Approval: |
|---------------|
| Date: |
| Construction: |
| Unit #: |
| Drawing #: |




Note:" Graphics in this document are for representation only. Actual model may differ in appearance."



ComfortStar®

Indoor unit dimension



| | Dimensions [IN.] | | | | | | | | |
|---------|------------------------|-----------------------|------------------------|-----------------------|------------------------|--|--|--|--|
| Model | Unit Height "H" IN. | Unit Width "W" IN. | Unit Width "W1" IN. | Unit Depth "D" IN. | Unit Depth "D1" IN. | Unit Weight/Shipping Weight Lbs. | | | |
| 18K/24K | 36-1/2 | 20-1/2 | 17-2/5 | 15 | 9-1/2 | 79/95 | | | |
| 30K/36K | 39-1/2 | 22 | 18-4/5 | 19 | 9-1/2 | 97/119 | | | |

CWM5-18-15R 2



Specification

| Model | | CWM5-18-15R |
|------------------------|--------------------------------|-------------|
| NOVALLA DATING | Cooling(BTU/h) External Static | 18000 |
| NOMINAL RATING | Pressure(in.w.c) | 0.7 |
| | Voltage /Phase(60Hz) | 208/230/1 |
| | Min./Max.Voltage | 187/253 |
| ELECTRICAL DATA | Min.Circuit Amps | 1 |
| | Max.Overcurrent Protection | 15 |
| | Motor Type | PSC |
| | Capacitor (uF) | 6 |
| FAN MOTOR | Horsepower (HP) | 1/6 |
| | Rated RPM | 1075 |
| | Full Load Amps (FLA) | 0.8 |
| | Material | Metal |
| FAN BLOWER | Туре | Centrifugal |
| PAN BLOWER | Diameter(in.) | 10-3/4 |
| | Height(in.) | 6 |
| | Туре | Tube &Fin |
| EVAPORATOR COIL | Tube Material | Aluminum |
| | Tube Size(in. | 9/32 |
| | Height | 36-1/2 |
| Unit Dimensions(inch) | Width | 20-1/2 |
| | Depth | 15 |
| SOUND POWER (dB) | | 50 |
| REFRIGERANT CONNECTION | SIZE Liquid Line Size (0.D.) | 3/8 |
| | Suction Line Size (0.D.) | 3/4 |

| Outdoor | Indoor | Cooling Capacity | EER2 | SEER2 | Heating Capacity | HSPF2 |
|-------------|-------------|------------------|------|-------|------------------|-------|
| MAH5-18-410 | CWM5-18-15R | 17400 | 11.2 | 13.4 | / | / |

3 CWM5-18-15R

Electric Heater Kits

| NO. Kit | | Description | Ref.Air Handler Use | | |
|---------|----------|---------------------------------------|------------------------|--|--|
| 1 | CHE2-05B | 5kW Heat Strip | 18/24/30/36 | | |
| 2 | CHE2-08B | 7.5kW Heat Strip | 18/24/30/36 | | |
| 3 | CHE2-10B | 10kW Heat Strip | 18/24/30/36 | | |
| 4 | CHE2-15B | 15kW Heat Strip, double Breaker panel | 18/24/30/36 | | |
| 5 | CHE2-20B | 20kW Heat Strip, double Breaker panel | 18/24/30/36 | | |

Electric Kit Mca/Mop Data

| Heater Kit Model Used | Air Handler Model | Electric Heat (kW) | Min. Circuit Ampacity | | Max. Fuse or Breaker (HACR) Ampacity | | Fan speed (AC/HP) | | |
|-----------------------------|-------------------------|-----------------------|--------------------------|-----------|---|-------|----------------------|--------|------|
| | | | 240V | 208V | 240V | 208V | Low | Medium | High |
| CHE2-05B | | 5 | 28.1 | 24.6 | 30 | 25 | • | • | • |
| CHE2-08B | 18 | 7.5 | 41.1 | 35.9 | 45 | 40 | • | | • |
| CHE2-10B | | 10 | 54.1 | 47.2 | 60 | 50 | • | • | • |
| CHE2-05B | 24 | 5 | 29 | 25.5 | 30 | 30 | • | • | • |
| CHE2-08B | | 7.5 | 42 | 36.8 | 45 | 40 | • | • | • |
| CHE2-10B | | 10 | 55 | 48.1 | 60 | 50 | • | • | • |
| CHE2-05B | | 5 | 29.4 | 25.9 | 30 | 30 | • | • | • |
| CHE2-08B | 30 | 7.5 | 42.4 | 37.2 | 45 | 40 | • | • | • |
| CHE2-10B | 30 | 10 | 55.4 | 48.5 | 60 | 50 | • | • | • |
| CHE2-15B | | 15 | 55.4/26.1 | 48.5/22.6 | 60/30 | 50/25 | • | • | • |
| CHE2-05B | | 5 | 29.4 | 25.9 | 30 | 30 | • | • | • |
| CHE2-08B | 36 | 7.5 | 42.4 | 37.2 | 45 | 40 | • | • | • |
| CHE2-10B | | 10 | 55.4 | 48.5 | 60 | 50 | • | • | • |
| CHE2-15B | | 15 | 55.4/26.1 | 48.5/22.6 | 60/30 | 50/25 | • | • | • |
| CHE2-20B | | 20 | 55.4/52.1 | 48.5/45.2 | 60/60 | 60/50 | • | • | • |

CWM5-18-15R 4



12201 N W 107th Avenue Miami, FL 33178 1.866.524.9898 Toll Free 305.500.9898 Office 305.500.9896 Fax http://www.comfortstarusa.com





The AHRI mark indicates Comfortstar participating in the AHRI Certification program. Visit ahridirectory.org for verification of individual certified products. Comfortstar reserves the right to change design and specs without notice. Comfortstar has a policy of update the data continuously.We are committed to using environmentally conscious print practices.

CWM5-18-15R 20 Nov 2023 Supersedes CWM5-18-15R (Nov.2023)