

ComfortStar®

Air Conditioning & Heating Products

In this document, you will discover every possible combination. Key considerations to keep in mind are highlighted in red at the bottom of this combinations chart. Be sure to review these notes, and if you have any questions before proceeding, please contact ComfortStar Tech Support.



Hi-Heat Series MULTI INDOOR UNITS COMBINATION RULE

Outdoor Unit	Available Indoor	Standard Combination	Two units	Three units	Four units	Five units	Six units
CVH3-18-3SH	Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K; Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I)/Ducted(CPA3); 6+6+6	6+6	6+6+6			
			6+9	6+6+9			
			6+12	6+6+12			
			6+18	6+6+18			
			6+24	6+6+24			
			9+9	6+9+9			
			9+12	6+9+12			
			9+18	6+9+18			
			9+24	6+12+12			
			12+12	6+12+18			
			12+18	9+9+9			
			12+24	9+9+12			
			18+18	9+9+18			
				9+12+12			
				12+12+12			
	When there One Way Cassette(T1W3) in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	/	6+6				
			6+9				
			6+12				
			6+18				
			6+24				
			9+9				
			9+12				
			9+18				
			9+24				
			12+12				
			12+18				
			12+24				
			18+18				
	When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K; AHU; 18K/24K	/	6+18	6+6+18			
			9+18	6+9+18			
			12+18	9+9+18			
	When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K; AHU; 18K/24K	/	6+18				
			9+18				
			12+18				
	Mid-static duct(CPA3H)(only); 9K/12K/18K/24K	Mid-static duct(CPA3H); 9+9	9+9				
			9+12				
			9+18				
			9+24				
			12+12				
			12+18				
			12+24				
			6+18	6+6+6	6+6+6+6		
			6+24	6+6+9	6+6+6+9		
			9+9	6+6+12	6+6+6+12		
			9+12	6+6+18	6+6+6+18		
			9+18	6+6+24	6+6+6+24		
			9+24	6+9+9	6+6+9+9		
			12+12	6+9+12	6+6+9+12		
			12+18	6+9+18	6+6+9+18		
			12+24	6+9+24	6+6+9+24		

CVH3-27-4SH

Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K; Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I)/Ducted(CPA3); 6+6+6+9	18+18	6+12+12	6+6+12+12		
			6+12+18	6+6+12+18		
			6+12+24	6+6+12+24		
			6+18+18	6+6+18+18		
			6+18+24	6+9+9+9		
			9+9+9	6+9+9+12		
			9+9+12	6+9+9+18		
			9+9+18	6+9+9+24		
			9+9+24	6+9+12+12		
			9+12+12	6+9+12+18		
			9+12+18	6+12+12+12		
			9+12+24	6+12+12+18		
			9+18+18	9+9+9+9		
			12+12+12	9+9+9+12		
			12+12+18	9+9+9+18		
			12+12+24	9+9+12+12		
			12+18+18	9+9+12+18		
				9+12+12+12		
				12+12+12+12		
		6+18	6+6+6			
		6+24	6+6+9			
		9+9	6+6+12			
		9+12	6+6+18			
		9+18	6+6+24			
		9+24	6+9+9			
		12+12	6+9+12			
		12+18	6+9+18			
		12+24	6+9+24			
		18+18	6+12+12			
When there One Way Cassette(T1W3) in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);			6+12+18			
			6+12+24			
			6+18+18			
			6+18+24			
			9+9+9			
			9+9+12			
			9+9+18			
			9+9+24			
			9+12+12			
			9+12+18			
			9+12+24			
			9+18+18			
			12+12+12			
			12+12+18			
			12+12+24			
			12+18+18			
When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K; AHU; 18K/24K/30K		6+18	6+6+18	6+6+6+18		
		6+24	6+6+24	6+6+6+24		
		9+18	6+9+18	6+6+9+18		
		9+24	6+9+24	6+6+9+24		
		12+18	6+12+18	6+9+9+18		
		12+24	6+12+24	6+9+9+24		
		18+18	9+9+18	9+9+9+18		
			9+9+24			
			9+12+18			
			9+12+24			
When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K; AHU; 18K/24K/30K			12+12+18			
			12+12+24			
		6+18	6+6+18			
		6+24	6+6+24			
		9+18	6+9+18			
		9+24	6+9+24			
		12+18	6+12+18			
		12+24	6+12+24			
		18+18	9+9+18			
			9+9+24			
			9+12+18			
			9+12+24			
			12+12+18			
			12+12+24			
		9+9	9+9+9			

	Mid-static duct(CPA3H)(only): 9K/12K/18K/24K	Mid-static duct(CPA3H): 9+9+9	9+12	9+9+12			
			9+18	9+9+18			
			9+24	9+9+24			
			12+12	9+12+12			
			12+18	9+12+18			
			12+24	9+12+24			
				12+12+12			
				12+12+18			
			12+12+24				
Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I)/Ducted(CPA3): 6+6+6+9+9	6+24	6+6+12	6+6+6+6	6+6+6+6+6		
		6+30	6+6+18	6+6+6+9	6+6+6+6+9		
		6+36	6+6+24	6+6+6+12	6+6+6+6+12		
		9+18	6+6+30	6+6+6+18	6+6+6+6+18		
		9+24	6+6+36	6+6+6+24	6+6+6+9+9		
		9+30	6+9+9	6+6+9+9	6+6+6+9+12		
		9+36	6+9+12	6+6+9+12	6+6+6+9+18		
		12+12	6+9+18	6+6+9+18	6+6+6+12+12		
		12+18	6+9+24	6+6+9+24	6+6+6+12+18		
		12+24	6+9+30	6+6+12+12	6+6+9+9+9		
		12+30	6+12+12	6+6+12+18	6+6+9+9+12		
		12+36	6+12+18	6+6+12+24	6+6+9+9+18		
		18+18	6+12+24	6+6+18+18	6+6+9+12+12		
		18+24	6+12+30	6+6+18+24	6+6+12+12+12		
		18+30	6+18+18	6+9+9+9	6+9+9+9+9		
		24+24	6+18+24	6+9+9+12	6+9+9+9+12		
			9+9+9	6+9+9+18	6+9+9+12+12		
			9+9+12	6+9+9+24	9+9+9+9+9		
			9+9+18	6+9+12+12	9+9+9+9+12		
			9+9+24	6+9+12+18			
			9+9+30	6+9+12+24			
			9+12+12	6+9+18+18			
			9+12+18	6+9+18+24			
			9+12+24	6+12+12+12			
			9+18+18	6+12+12+18			
			9+18+24	6+12+12+24			
			12+12+12	6+12+18+18			
			12+12+18	6+12+18+24			
			12+12+24	6+18+18+18			
			12+18+18	9+9+9+9			
			12+18+24	9+9+9+12			
			18+18+18	9+9+9+18			
				9+9+9+24			
				9+9+12+12			
				9+9+12+18			
				9+9+12+24			
				9+9+18+18			
				9+9+18+24			
				9+12+12+12			
				9+12+12+18			
				9+12+12+24			
				9+12+18+18			
				9+18+18+18			
				12+12+12+12			
				12+12+12+18			
				12+12+12+24			
				12+12+18+18			
		6+24	6+6+12	6+6+6+6			
		6+30	6+6+18	6+6+6+9			
		6+36	6+6+24	6+6+6+12			
		9+18	6+6+30	6+6+6+18			
		9+24	6+6+36	6+6+6+24			
		9+30	6+9+9	6+6+9+9			
		9+36	6+9+12	6+6+9+12			
		12+12	6+9+18	6+6+9+18			
		12+18	6+9+24	6+6+9+24			
		12+24	6+9+30	6+6+12+12			
		12+30	6+12+12	6+6+12+18			
		12+36	6+12+18	6+6+12+24			
		18+18	6+12+24	6+6+18+18			

CVH3-36-5SH

When there One Way Cassette(T1W3) in the combination:
Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K;
Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K;
Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);

When there AHU in the combination:
Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K;
Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K;
AHU; 18K/24K/30K/36K

When there One Way Cassette(T1W3) and AHU both in the combination:
Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K;
Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K;
AHU; 18K/24K/30K/36K

18+24	6+12+30	6+6+18+24		
18+30	6+18+18	6+9+9+9		
24+24	6+18+24	6+9+9+12		
	9+9+9	6+9+9+18		
	9+9+12	6+9+9+24		
	9+9+18	6+9+12+12		
	9+9+24	6+9+12+18		
	9+9+30	6+9+12+24		
	9+12+12	6+9+18+18		
	9+12+18	6+9+18+24		
	9+12+24	6+12+12+12		
	9+18+18	6+12+12+18		
	9+18+24	6+12+12+24		
	12+12+12	6+12+18+18		
	12+12+18	6+12+18+24		
	12+12+24	6+18+18+18		
	12+18+18	9+9+9+9		
	12+18+24	9+9+9+12		
	18+18+18	9+9+9+18		
		9+9+9+24		
		9+9+12+12		
		9+9+12+18		
		9+9+12+24		
		9+9+18+18		
		9+9+18+24		
		9+12+12+12		
		9+12+12+18		
		9+12+12+24		
		9+12+18+18		
		9+18+18+18		
		12+12+12+12		
		12+12+12+18		
		12+12+12+24		
		12+12+18+18		
6+18	6+6+18	6+6+6+18	6+6+6+6+18	
6+24	6+6+24	6+6+6+24	6+6+6+9+18	
6+30	6+6+30	6+6+9+18	6+6+9+9+18	
6+36	6+6+36	6+6+9+24		
9+18	6+9+18	6+6+12+18		
9+24	6+9+24	6+6+12+24		
9+30	6+9+30	6+9+9+18		
9+36	6+12+18	6+9+9+24		
12+18	6+12+24	6+9+12+18		
12+24	6+12+30	6+9+12+24		
12+30	9+9+18	6+12+12+18		
12+36	9+9+24	6+12+12+24		
18+18	9+9+30	9+9+9+18		
18+24	9+12+18	9+9+9+24		
18+30	9+12+24	9+9+12+18		
24+24	12+12+18	9+9+12+24		
	12+12+24	9+12+12+18		
		9+12+12+24		
		12+12+12+18		
		12+12+12+24		
6+18	6+6+18	6+6+6+18		
6+24	6+6+24	6+6+6+24		
6+30	6+6+30	6+6+9+18		
6+36	6+6+36	6+6+9+24		
9+18	6+9+18	6+6+12+18		
9+24	6+9+24	6+6+12+24		
9+30	6+9+30	6+9+9+18		
9+36	6+12+18	6+9+9+24		
12+18	6+12+24	6+9+12+18		
12+24	6+12+30	6+9+12+24		
12+30	9+9+18	6+12+12+18		
12+36	9+9+24	6+12+12+24		
18+18	9+9+30	9+9+9+18		
18+24	9+12+18	9+9+9+24		
18+30	9+12+24	9+9+12+18		
24+24	12+12+18	9+9+12+24		

CVH3-48-6SH

CVH3-60-6SH

When there One Way Cassette(T1W3) in the combination:
Wall mounted(CPP3(I)), 6K/9K/12K/18K/24K/30K/36K;
Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K;
Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);

			9+9+9+9+18	9+9+9+9+24
			9+9+9+9+24	9+9+9+9+12+12
			9+9+9+12+12	9+9+9+9+12+18
			9+9+9+12+18	9+9+9+9+12+24
			9+9+9+12+24	9+9+9+12+12+12
			9+9+9+18+18	9+9+9+12+12+18
			9+9+9+18+24	9+9+12+12+12+12
			9+9+12+12+12	9+9+12+12+12+18
			9+9+12+12+18	9+12+12+12+12+12
			9+9+12+12+24	12+12+12+12+12+12
			9+9+12+18+18	
			9+9+12+18+24	
			9+9+18+18+18	
			9+12+12+12+12	
			9+12+12+12+18	
			9+12+12+12+24	
			9+12+12+18+18	
			12+12+12+12+12	
			12+12+12+12+18	
			12+12+12+12+24	
			12+12+12+18+18	
6+24	6+6+18	6+6+6+6	6+6+6+6+6	
6+30	6+6+24	6+6+6+9	6+6+6+6+9	
6+36	6+6+30	6+6+6+12	6+6+6+6+12	
9+18	6+6+36	6+6+6+18	6+6+6+6+18	
9+24	6+9+9	6+6+6+24	6+6+6+6+24	
9+30	6+9+12	6+6+9+9	6+6+6+9+9	
9+36	6+9+18	6+6+9+12	6+6+6+9+12	
12+12	6+9+24	6+6+9+18	6+6+6+9+18	
12+18	6+9+30	6+6+9+24	6+6+6+9+24	
12+24	6+9+36	6+6+12+12	6+6+6+12+12	
12+30	6+12+12	6+6+12+18	6+6+6+12+18	
12+36	6+12+18	6+6+12+24	6+6+6+12+24	
18+18	6+12+24	6+6+18+18	6+6+6+18+18	
18+24	6+12+30	6+6+18+24	6+6+6+18+24	
18+30	6+12+36	6+9+9+9	6+6+9+9+9	
18+36	6+18+18	6+9+9+12	6+6+9+9+12	
24+24	6+18+24	6+9+9+18	6+6+9+9+18	
24+30	6+18+30	6+9+9+24	6+6+9+9+24	
24+36	6+18+36	6+9+12+12	6+6+9+12+12	
	9+9+9	6+9+12+18	6+6+9+12+18	
	9+9+12	6+9+12+24	6+6+9+12+24	
	9+9+18	6+9+18+18	6+6+9+18+18	
	9+9+24	6+9+18+24	6+6+9+18+24	
	9+9+30	6+12+12+12	6+6+12+12+12	
	9+9+36	6+12+12+18	6+6+12+12+18	
	9+12+12	6+12+12+24	6+6+12+12+24	
	9+12+18	6+12+18+18	6+6+12+18+18	
	9+12+24	6+12+18+24	6+6+12+18+24	
	9+12+30	6+18+18+18	6+6+18+18+18	
	9+12+36	6+18+18+24	6+6+18+18+24	
	9+18+18	9+9+9+9	6+9+9+9+9	
	9+18+24	9+9+9+12	6+9+9+9+12	
	9+18+30	9+9+9+18	6+9+9+9+18	
	9+18+36	9+9+9+24	6+9+9+9+24	
	12+12+12	9+9+12+12	6+9+9+12+12	
	12+12+18	9+9+12+18	6+9+9+12+18	
	12+12+24	9+9+12+24	6+9+9+12+24	
	12+12+30	9+9+18+18	6+9+9+18+18	
	12+12+36	9+9+18+24	6+9+9+18+24	
	12+18+18	9+12+12+12	6+9+12+12+12	
	12+18+24	9+12+12+18	6+9+12+12+18	
	12+18+30	9+12+12+24	6+9+12+12+24	
	12+18+36	9+12+18+18	6+9+12+18+18	
	18+18+18	9+12+18+24	6+9+12+18+24	
		9+18+18+18	6+9+18+18+18	
		12+12+12+12	6+12+12+12+12	
		12+12+12+18	6+12+12+12+18	
		12+12+12+24	6+12+12+12+24	
		12+12+18+18	6+12+12+18+18	

				12+12+18+24	6+12+18+18+18	
				12+18+18+18	9+9+9+9+9	
					9+9+9+9+12	
					9+9+9+9+18	
					9+9+9+9+24	
					9+9+9+12+12	
					9+9+9+12+18	
					9+9+9+12+24	
					9+9+9+18+18	
					9+9+9+18+24	
					9+9+12+12+12	
					9+9+12+12+18	
					9+9+12+12+24	
					9+9+12+18+18	
					9+9+12+18+24	
					9+9+18+18+18	
					9+12+12+12+12	
					9+12+12+12+18	
					9+12+12+12+24	
					9+12+12+18+18	
					12+12+12+12+12	
					12+12+12+12+18	
					12+12+12+12+24	
					12+12+12+18+18	
					12+12+12+18+18	
When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; AHU; 18K/24K/30K/36K		6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
		6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
		6+30	6+6+30	6+6+9+18	6+6+6+12+18	6+6+6+9+9+18
		6+36	6+6+36	6+6+9+24	6+6+6+12+24	6+6+9+9+9+18
		9+18	6+9+18	6+6+12+18	6+9+9+9+18	6+9+9+9+9+18
		9+24	6+9+24	6+6+12+24	6+9+9+9+24	9+9+9+9+9+18
		9+30	6+9+30	6+9+9+18	6+9+9+12+18	
		9+36	6+9+36	6+9+9+24	6+9+9+12+24	
		12+18	6+12+18	6+9+12+18	6+9+12+12+18	
		12+24	6+12+24	6+9+12+24	6+9+12+12+24	
		12+30	6+12+30	6+12+12+18	6+12+12+12+18	
		12+36	6+12+36	6+12+12+24	9+9+9+9+18	
		18+18	9+9+18	9+9+9+18	9+9+9+9+24	
		18+24	9+9+24	9+9+9+24	9+9+9+12+24	
		18+30	9+9+30	9+9+12+18	9+9+9+12+18	
		18+36	9+9+36	9+9+12+24	9+9+12+12+18	
		24+24	9+12+18	9+12+12+18	9+12+12+12+18	
		24+30	9+12+24	9+12+12+24		
		24+36	9+12+30	12+12+12+18		
			9+12+36	12+12+12+24		
When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; AHU; 18K/24K/30K/36K			12+12+18			
			12+12+24			
			12+12+30			
		6+18	6+6+18	6+6+6+18	6+6+6+6+18	
		6+24	6+6+24	6+6+6+24	6+6+6+6+24	
		6+30	6+6+30	6+6+9+18	6+6+6+12+18	
		6+36	6+6+36	6+6+9+24	6+6+6+12+24	
		9+18	6+9+18	6+6+12+18	6+9+9+9+18	
		9+24	6+9+24	6+6+12+24	6+9+9+9+24	
		9+30	6+9+30	6+9+9+18	6+9+9+12+18	
		9+36	6+9+36	6+9+9+24	6+9+9+12+24	
		12+18	6+12+18	6+9+12+18	6+9+12+12+18	
		12+24	6+12+24	6+9+12+24	6+9+12+12+24	
		12+30	6+12+30	6+12+12+18	6+12+12+12+18	
		12+36	6+12+36	6+12+12+24	9+9+9+9+18	
		18+18	9+9+18	9+9+9+18	9+9+9+9+24	
		18+24	9+9+24	9+9+9+24	9+9+9+12+24	
		18+30	9+9+30	9+9+12+18	9+9+9+12+18	
		18+36	9+9+36	9+9+12+24	9+9+12+12+18	
		24+24	9+12+18	9+12+12+18	9+12+12+12+18	
		24+30	9+12+24	9+12+12+24		
		24+36	9+12+30	12+12+12+18		
			9+12+36	12+12+12+24		
			12+12+18			
			12+12+24			
			12+12+30			

Mid-static duct(CPA3H)(only): 9K/12K/18K/24K	Mid-static duct(CPA3H): 9+9+12+12+12	9+9	9+9+9	9+9+9+9	9+9+9+9+9	
		9+12	9+9+12	9+9+9+12	9+9+9+9+12	
		9+18	9+9+18	9+9+9+18	9+9+9+12+12	
		9+24	9+9+24	9+9+9+24	9+9+12+12+12	
		12+12	9+12+12	9+9+12+12	9+12+12+12+12	
		12+18	9+12+18	9+9+12+18	12+12+12+12+12	
		12+24	9+12+24	9+9+12+24		
		18+18	9+18+18	9+9+18+18		
		18+24	9+18+24	9+9+18+24		
		24+24	9+24+24	9+12+12+12		
			12+12+12	9+12+12+18		
			12+12+18	9+12+12+24		
			12+12+24	9+12+18+18		
			12+18+18	9+12+18+24		
			12+18+24	12+12+12+12		
			12+24+24	12+12+12+18		
				12+12+12+24		
				12+12+18+18		
				12+12+18+24		
				12+12+18+24		

Key Considerations for Indoor and Outdoor Unit Load Management

If the total load of indoor units surpasses the nominal capacity of the outdoor unit, the effective output capacity of each indoor unit will be reduced accordingly. This is particularly noticeable during the heating mode. When the indoor units are of the same size, smaller indoor units can be combined with units of the same size. For instance, since the capacities of 9K and 12K units are identical, the 12K unit can be treated as a 9K unit when forming combinations with 9K units. For optimal efficiency, a 12K unit should be regarded as an 18K unit in the combination chart, as it shares the same size as a standard 18K unit.

Regarding the AHU series:

- The AHU fan will either stop (Follow Me On) or run intermittently (Follow Me Off) once the set temperature is reached.
- If connected to a third-party thermostat via a 24V connection, the fan ON command from the thermostat will be ineffective if there is no heating demand from the AHU, meaning the fan will not activate.
- The system will commence operation when the AHU receives an emergency heating demand.