

ComfortStar®

Air Conditioning & Heating Products

In this document, you will discover every possible combination. Key considerations to keep in mind are highlighted in red at the bottom of this combinations chart. Be sure to review these notes, and if you have any questions before proceeding, please contact ComfortStar Tech Support.



Platinum Series MULTI INDOOR UNITS COMBINATION RULE

Outdoor Unit	Available Indoor	Standard Combination					
			Two units	Three units	Four units	Five units	Six units
CMZ3-24-3Z	Wall mounted CPP3(I); 6K/9K/12K/18K; Cassette(TPA3&TIP3) /Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K; Mid-static duct(CPA3H); 9K/12K (should be considered as 18K)	Wall mounted CPP3(I),Ducted(CPA3); 6+6+6	6+6	6+6+6			
			6+9	6+6+9			
			6+12	6+9+9			
			6+18				
			9+9				
			9+12				
			12+12				
	When there One Way Cassette(T1W3) in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/CPA3/Floor Ceiling(FPA3); 6K/9K/12K/18K; Mid-static duct(CPA3H); 9K/12K (should be considered as 18K)	/	6+6				
			6+9				
			6+12				
			6+18				
			9+9				
			9+12				
			12+12				
	Mid-static duct(CPA3H)(only); 9K/12K	Mid-static duct(CPA3H); 9+9	9+9				
			9+12				
			12+12				
CMZ3-30-4Z	Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K; Cassette(TPA3&TIP3)/CPA3/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I),Ducted(CPA3); 6+6+6+9	6+6	6+6+6	6+6+6+6		
			6+9	6+6+9	6+6+6+9		
			6+12	6+6+12	6+6+6+12		
			6+18	6+6+18	6+6+9+9		
			6+24	6+6+24	6+6+9+12		
			9+9	6+9+9	6+9+9+9		
			9+12	6+9+12	6+9+9+12		
			9+18	6+9+18	9+9+9+9		
			9+24	6+12+12			
			12+12	6+12+18			
			12+18	9+9+9			
			12+24	9+9+12			
			18+18	9+9+18			
				9+12+12			
				12+12+12			
	When there One Way Cassette(T1W3) in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	/	6+6	6+6+6			
			6+9	6+6+9			
			6+12	6+6+12			
			6+18	6+6+18			
			6+24	6+6+24			
			9+9	6+9+9			
			9+12	6+9+12			
			9+18	6+9+18			
			9+24	6+12+12			
			12+12	6+12+18			
			12+18	9+9+9			
			12+24	9+9+12			
			18+18	9+9+18			
				9+12+12			
				12+12+12			
	When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K; AHU; 18K/24K	/	6+18	6+6+18			
			9+18	6+9+18			
			12+18	9+9+18			
	When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K;		6+18				
			9+18				

	Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K; AHU; 18K/24K	/		12+18					
	Mid-static duct(CPA3H)(only); 9K/12K/18K/24K	Mid-static duct(CPA3H); 9+18		9+9					
			9+12						
			9+18						
			9+24						
			12+12						
			12+18						
			12+24						
CMZ3-48-5Z	Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K; Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I)/Ducted(CPA3); 6+6+6+9+9		6+18	6+6+6	6+6+6+6	6+6+6+6+6		
				6+24	6+6+9	6+6+6+9	6+6+6+6+9		
				9+9	6+6+12	6+6+6+12	6+6+6+6+12		
				9+12	6+6+18	6+6+6+18	6+6+6+6+18		
				9+18	6+6+24	6+6+6+24	6+6+6+9+9		
				9+24	6+9+9	6+6+9+9	6+6+6+9+12		
				12+12	6+9+12	6+6+9+12	6+6+6+9+18		
				12+18	6+9+18	6+6+9+18	6+6+9+9+9		
				12+24	6+9+24	6+6+9+24	6+6+9+9+12		
				18+18	6+12+12	6+6+12+12	6+6+9+9+18		
					6+12+18	6+6+12+18	6+9+9+9+9		
					6+12+24	6+6+12+24	6+9+9+9+12		
					6+18+18	6+6+18+18	6+9+9+9+18		
					9+9+9	6+9+9+9	9+9+9+9+9		
					9+9+12	6+9+9+12	9+9+9+9+12		
					9+9+18	6+9+9+18			
					9+9+24	6+9+9+24			
					9+12+12	6+9+12+12			
					9+12+18	6+9+12+18			
					9+12+24	6+12+12+12			
					9+18+18	6+12+12+18			
					12+12+12	9+9+9+9			
					12+12+18	9+9+9+12			
					12+12+24	9+9+9+18			
					12+18+18	9+9+12+12			
						9+9+12+18			
						9+12+12+12			
						12+12+12+12			
	When there One Way Cassette(T1W3) in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	/		6+18	6+6+6	6+6+6+6			
				6+24	6+6+9	6+6+6+9			
				9+9	6+6+12	6+6+6+12			
				9+12	6+6+18	6+6+6+18			
				9+18	6+6+24	6+6+6+24			
				9+24	6+9+9	6+6+9+9			
				12+12	6+9+12	6+6+9+12			
				12+18	6+9+18	6+6+9+18			
				12+24	6+9+24	6+6+9+24			
				18+18	6+12+12	6+6+12+12			
					6+12+18	6+6+12+18			
					6+12+24	6+6+12+24			
					6+18+18	6+6+18+18			
					9+9+9	6+9+9+9			
					9+9+12	6+9+9+12			
					9+9+18	6+9+9+18			
					9+9+24	6+9+9+24			
					9+12+12	6+9+12+12			
					9+12+18	6+9+12+18			
					9+12+24	6+12+12+12			
					9+18+18	6+12+12+18			
					12+12+12	9+9+9+9			
					12+12+18	9+9+9+12			
					12+12+24	9+9+9+18			
					12+18+18	9+9+12+12			
						9+9+12+18			
						9+12+12+12			
						12+12+12+12			
					6+18	6+6+18	6+6+6+18	6+6+6+6+18	
					6+24	6+6+24	6+6+6+24	6+6+6+9+18	
					9+18	6+9+18	6+6+9+18	6+6+9+9+18	

	When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K; AHU; 18K/24K/30K	/	9+24	6+9+24	6+6+9+24	6+9+9+9+18	
			12+18	6+12+18	6+6+12+18		
			12+24	6+12+24	6+6+12+24		
	When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K; AHU; 18K/24K/30K	/	18+18	9+9+18	6+9+9+18		
				9+9+24	6+9+9+24		
				9+12+18	6+9+12+18		
	Mid-static duct(CPA3H)(only); 9K/12K/18K/24K	Mid-static duct(CPA3H); 12+12+12		9+12+24	6+12+12+18		
				12+12+18	9+9+9+18		
				12+12+24	9+9+12+18		
			6+18	6+6+18	6+6+6+18		
			6+24	6+6+24	6+6+6+24		
			9+18	6+9+18	6+6+9+18		
			9+24	6+9+24	6+6+9+24		
			12+18	6+12+18	6+6+12+18		
			12+24	6+12+24	6+6+12+24		
			18+18	9+9+18	6+9+9+18		
				9+9+24	6+9+9+24		
				9+12+18	6+9+12+18		
				9+12+24	6+12+12+18		
				12+12+18	9+9+9+18		
				12+12+24	9+9+12+18		
			9+9	9+9+9			
			9+12	9+9+12			
			9+18	9+9+18			
			9+24	9+9+24			
			12+12	9+12+12			
			12+18	9+12+18			
			12+24	9+12+24			
				12+12+12			
				12+12+18			
				12+12+24			
			6+24	6+6+18	6+6+6+6	6+6+6+6+6	
			6+30	6+6+24	6+6+6+9	6+6+6+6+9	
			6+36	6+6+30	6+6+6+18	6+6+6+6+12	6+6+6+6+6+12
			9+18	6+6+36	6+6+6+24	6+6+6+6+18	6+6+6+6+6+18
			9+24	6+9+12	6+6+9+9	6+6+6+6+24	6+6+6+6+9+9
			9+30	6+9+18	6+6+9+12	6+6+6+9+9	6+6+6+6+9+12
			9+36	6+9+24	6+6+9+18	6+6+6+9+12	6+6+6+6+9+18
			12+12	6+9+30	6+6+9+24	6+6+6+9+18	6+6+6+6+12+12
			12+18	6+9+36	6+6+12+12	6+6+6+9+24	6+6+6+6+12+18
			12+24	6+12+18	6+6+12+18	6+6+6+12+12	6+6+6+9+9
			12+30	6+12+24	6+6+12+24	6+6+6+12+18	6+6+6+9+12
			12+36	6+12+30	6+6+18+18	6+6+6+12+24	6+6+6+6+9+18
			18+18	6+12+36	6+6+18+24	6+6+6+18+18	6+6+6+9+12+12
			18+24	6+18+18	6+9+9+9	6+6+6+18+24	6+6+6+9+12+18
			18+30	6+18+24	6+9+9+12	6+6+9+9+9	6+6+6+12+12+12
			18+36	6+18+30	6+9+9+18	6+6+9+9+12	6+6+6+12+12+18
			24+24	6+18+36	6+9+9+24	6+6+9+9+18	6+6+9+9+9+9
			24+30	9+9+9	6+9+12+12	6+6+9+9+24	6+6+9+9+9+12
			24+36	9+9+12	6+9+12+18	6+6+9+12+12	6+6+9+9+9+18
				9+9+18	6+9+12+24	6+6+9+12+18	6+6+9+9+12+12
				9+9+24	6+9+18+18	6+6+9+12+24	6+6+9+9+12+18
				9+9+30	6+9+18+24	6+6+9+18+18	6+6+9+12+12+12
				9+9+36	6+12+12+12	6+6+9+18+24	6+6+9+12+12+18
				9+12+12	6+12+12+18	6+6+12+12+12	6+9+9+9+9+9
				9+12+18	6+12+12+24	6+6+12+12+18	6+9+9+9+9+12
				9+12+24	6+12+18+18	6+6+12+12+24	6+9+9+9+9+18
				9+12+30	6+12+18+24	6+6+12+18+18	6+9+9+9+12+12
				9+12+36	9+9+9+9	6+9+9+9+9	6+9+9+9+12+18
				9+18+18	9+9+9+12	6+9+9+9+12	6+9+9+12+12+12
				9+18+24	9+9+9+18	6+9+9+9+18	9+9+9+9+9+9
				9+18+30	9+9+9+24	6+9+9+9+24	9+9+9+9+9+12
				9+18+36	9+9+12+12	6+9+9+12+12	9+9+9+9+9+18
				12+12+12	9+9+12+18	6+9+9+12+18	9+9+9+9+12+12
				12+12+18	9+9+12+24	6+9+9+12+24	9+9+9+12+12+12
				12+12+24	9+9+18+18	6+9+9+18+18	
				12+12+30	9+9+18+24	6+9+12+12+12	
				12+12+36	9+12+12+12	6+9+12+12+18	
				12+18+18	9+12+12+18	6+9+12+12+24	
	Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; Mid-static duct(CPA3H); 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K);	Wall mounted CPP3(I)/Ducted(CPA3); 9+9+9+9+9					

CMZ3-55-6Z

When there One Way Cassette(T1W3) in the combination:
 Wall
 mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K;
 Cassette(TPA3&TIP3)/One Way
 Cassette(T1W3)/Ducted(CPA3)/Floor
 Ceiling(FPA3); 6K/9K/12K/18K/24K;
 Mid-static duct(CPA3H); 9K/12K(should be
 considered as 18K); 18K/24K(should be
 considered as 24K);

	12+18+24	9+12+12+24	6+9+12+18+18	
	12+18+30	9+12+18+18	6+12+12+12+12	
	18+18+18	9+12+18+24	6+12+12+12+18	
		9+18+18+18	9+9+9+9+9	
		12+12+12+12	9+9+9+9+12	
		12+12+12+18	9+9+9+9+18	
		12+12+12+24	9+9+9+9+24	
		12+12+18+18	9+9+9+12+12	
			9+9+9+12+18	
			9+9+9+12+24	
			9+9+9+18+18	
			9+9+12+12+12	
			9+9+12+12+18	
			9+12+12+12+12	
			9+12+12+12+18	
			12+12+12+12+12	
6+24	6+6+18	6+6+6+6	6+6+6+6+6	
6+30	6+6+24	6+6+6+9	6+6+6+6+9	
6+36	6+6+30	6+6+6+18	6+6+6+6+12	
9+18	6+6+36	6+6+6+24	6+6+6+6+18	
9+24	6+9+12	6+6+9+9	6+6+6+6+24	
9+30	6+9+18	6+6+9+12	6+6+6+9+9	
9+36	6+9+24	6+6+9+18	6+6+6+9+12	
12+12	6+9+30	6+6+9+24	6+6+6+9+18	
12+18	6+9+36	6+6+12+12	6+6+6+9+24	
12+24	6+12+18	6+6+12+18	6+6+6+12+12	
12+30	6+12+24	6+6+12+24	6+6+6+12+18	
12+36	6+12+30	6+6+18+18	6+6+6+12+24	
18+18	6+12+36	6+6+18+24	6+6+6+18+18	
18+24	6+18+18	6+9+9+9	6+6+6+18+24	
18+30	6+18+24	6+9+9+12	6+6+9+9+9	
18+36	6+18+30	6+9+9+18	6+6+9+9+12	
24+24	6+18+36	6+9+9+24	6+6+9+9+18	
24+30	9+9+9	6+9+12+12	6+6+9+9+24	
24+36	9+9+12	6+9+12+18	6+6+9+12+12	
	9+9+18	6+9+12+24	6+6+9+12+18	
	9+9+24	6+9+18+18	6+6+9+12+24	
	9+9+30	6+9+18+24	6+6+9+18+18	
	9+9+36	6+12+12+12	6+6+9+18+24	
	9+12+12	6+12+12+18	6+6+12+12+12	
	9+12+18	6+12+12+24	6+6+12+12+18	
	9+12+24	6+12+18+18	6+6+12+12+24	
	9+12+30	6+12+18+24	6+6+12+18+18	
	9+12+36	9+9+9+9	6+9+9+9+9	
	9+18+18	9+9+9+12	6+9+9+9+12	
	9+18+24	9+9+9+18	6+9+9+9+18	
	9+18+30	9+9+9+24	6+9+9+9+24	
	9+18+36	9+9+12+12	6+9+9+12+12	
	12+12+12	9+9+12+18	6+9+9+12+18	
	12+12+18	9+9+12+24	6+9+9+12+24	
	12+12+24	9+9+18+18	6+9+9+18+18	
	12+12+30	9+9+18+24	6+9+12+12+12	
	12+12+36	9+12+12+12	6+9+12+12+18	
	12+18+18	9+12+12+18	6+9+12+12+24	
	12+18+24	9+12+12+24	6+9+12+18+18	
	12+18+30	9+12+18+18	6+12+12+12+12	
	18+18+18	9+12+18+24	6+12+12+12+18	
		9+18+18+18	9+9+9+9+9	
		12+12+12+12	9+9+9+9+12	
		12+12+12+18	9+9+9+9+18	
		12+12+12+24	9+9+9+9+24	
		12+12+18+18	9+9+9+12+12	
			9+9+9+12+18	
			9+9+9+12+24	
			9+9+9+18+18	
			9+9+12+12+12	
			9+9+12+12+18	
			9+12+12+12+12	
			9+12+12+12+18	
			12+12+12+12+12	

			6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
			6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
			6+30	6+6+30	6+6+9+18	6+6+6+9+18	6+6+6+9+9+18
When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; AHU; 18K/24K/30K/36K			6+36	6+6+36	6+6+9+24	6+6+6+9+24	6+6+9+9+9+18
			9+18	6+9+18	6+6+12+18	6+6+6+12+18	6+9+9+9+9+18
			9+24	6+9+24	6+6+12+24	6+6+6+12+24	9+9+9+9+9+18
			9+30	6+9+30	6+9+9+18	6+9+9+9+18	
			9+36	6+9+36	6+9+9+24	6+9+9+9+24	
			12+18	6+12+18	6+9+12+18	6+9+9+12+18	
			12+24	6+12+24	6+9+12+24	6+9+9+12+24	
			12+30	6+12+30	6+12+12+18	6+9+12+12+18	
			12+36	6+12+36	6+12+12+24	6+9+12+12+24	
			18+18	9+9+18	9+9+9+18	6+12+12+12+18	
			18+24	9+9+24	9+9+9+24	9+9+9+9+18	
			18+30	9+9+30	9+9+12+18	9+9+9+9+24	
			18+36	9+9+36	9+9+12+24	9+9+9+12+24	
			24+24	9+12+18	9+12+12+18	9+9+9+12+18	
			24+30	9+12+24	9+12+12+24	9+9+12+12+18	
			24+36	9+12+30	12+12+12+18	9+12+12+12+18	
				9+12+36	12+12+12+24		
				12+12+18			
				12+12+24			
				12+12+30			
When there One Way Cassette(T1W3) and AHU both in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; AHU; 18K/24K/30K/36K			6+18	6+6+18	6+6+6+18	6+6+6+6+18	
			6+24	6+6+24	6+6+6+24	6+6+6+6+24	
			6+30	6+6+30	6+6+9+18	6+6+6+9+18	
			6+36	6+6+36	6+6+9+24	6+6+6+9+24	
			9+18	6+9+18	6+6+12+18	6+6+6+12+18	
			9+24	6+9+24	6+6+12+24	6+6+6+12+24	
			9+30	6+9+30	6+9+9+18	6+9+9+9+18	
			9+36	6+9+36	6+9+9+24	6+9+9+9+24	
			12+18	6+12+18	6+9+12+18	6+9+9+12+18	
			12+24	6+12+24	6+9+12+24	6+9+9+12+24	
			12+30	6+12+30	6+12+12+18	6+9+12+12+18	
			12+36	6+12+36	6+12+12+24	6+9+12+12+24	
			18+18	9+9+18	9+9+9+18	6+12+12+12+18	
			18+24	9+9+24	9+9+9+24	9+9+9+9+18	
			18+30	9+9+30	9+9+12+18	9+9+9+9+24	
			18+36	9+9+36	9+9+12+24	9+9+9+12+24	
			24+24	9+12+18	9+12+12+18	9+9+9+12+18	
			24+30	9+12+24	9+12+12+24	9+9+12+12+18	
			24+36	9+12+30	12+12+12+18	9+12+12+12+18	
				9+12+36	12+12+12+24		
				12+12+18			
				12+12+24			
				12+12+30			
Mid-static duct(CPA3H)(only); 9K/12K/18K/24K	Mid-static duct(CPA3H); 12+12+12+12		9+9	9+9+9	9+9+9+9		
			9+12	9+9+12	9+9+9+12		
			9+18	9+9+18	9+9+9+18		
			9+24	9+9+24	9+9+9+24		
			12+12	9+12+12	9+9+12+12		
			12+18	9+12+18	9+9+12+18		
			12+24	9+12+24	9+9+12+24		
			18+18	12+12+12	9+12+12+12		
			18+24	12+12+18	9+12+12+18		
			24+24	12+12+24	9+12+12+24		
					12+12+12+12		
					12+12+12+18		
					12+12+12+24		
			6+24	6+6+18	6+6+6+6	6+6+6+6+6	6+6+6+6+6+6
			6+30	6+6+24	6+6+6+9	6+6+6+6+9	6+6+6+6+6+9
			6+36	6+6+30	6+6+6+12	6+6+6+6+12	6+6+6+6+6+12
			9+18	6+6+36	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
			9+24	6+9+9	6+6+6+24	6+6+6+6+24	6+6+6+6+6+24
			9+30	6+9+12	6+6+9+9	6+6+6+9+9	6+6+6+6+9+9
			9+36	6+9+18	6+6+9+12	6+6+6+9+12	6+6+6+6+9+12
			12+12	6+9+24	6+6+9+18	6+6+6+9+18	6+6+6+6+9+18
			12+18	6+9+30	6+6+9+24	6+6+6+9+24	6+6+6+6+9+24
			12+24	6+9+36	6+6+12+12	6+6+6+12+12	6+6+6+6+12+12

Wall
mounted(CPP3(I)), 6K/9K/12K/18K/24K/30K/36K;
Cassette(TPA3&TIP3)/Ducted(CPA3)/Floor
Ceiling(FPA3), 6K/9K/12K/18K/24K;
Mid-static duct(CPA3H); 9K/12K(should be
considered as 18K); 18K/24K(should be
considered as 24K);

Wall mounted
CPP3(I)/Ducted(CPA3);
9+9+9+9+24

12+30	6+12+12	6+6+12+18	6+6+6+12+18	6+6+6+6+12+18
12+36	6+12+18	6+6+12+24	6+6+6+12+24	6+6+6+6+12+24
18+18	6+12+24	6+6+18+18	6+6+6+18+18	6+6+6+9+9+9
18+24	6+12+30	6+6+18+24	6+6+6+18+24	6+6+6+9+9+12
18+30	6+12+36	6+9+9+9	6+6+9+9+9	6+6+6+9+9+18
18+36	6+18+18	6+9+9+12	6+6+9+9+12	6+6+6+9+9+24
24+24	6+18+24	6+9+9+18	6+6+9+9+18	6+6+6+9+12+12
24+30	6+18+30	6+9+9+24	6+6+9+9+24	6+6+6+9+12+18
24+36	6+18+36	6+9+12+12	6+6+9+12+12	6+6+6+9+12+24
	9+9+9	6+9+12+18	6+6+9+12+18	6+6+6+12+12+12
	9+9+12	6+9+12+24	6+6+9+12+24	6+6+6+12+12+18
	9+9+18	6+9+18+18	6+6+9+18+18	6+6+6+12+12+24
	9+9+24	6+9+18+24	6+6+9+18+24	6+6+9+9+9+9
	9+9+30	6+12+12+12	6+6+12+12+12	6+6+9+9+9+12
	9+9+36	6+12+12+18	6+6+12+12+18	6+6+9+9+9+18
	9+12+12	6+12+12+24	6+6+12+12+24	6+6+9+9+9+24
	9+12+18	6+12+18+18	6+6+12+18+18	6+6+9+9+12+12
	9+12+24	6+12+18+24	6+6+12+18+24	6+6+9+9+12+18
	9+12+30	6+18+18+18	6+6+18+18+18	6+6+9+9+12+24
	9+12+36	6+18+18+24	6+6+18+18+24	6+6+9+12+12+12
	9+18+18	9+9+9+9	6+9+9+9+9	6+6+9+12+12+18
	9+18+24	9+9+9+12	6+9+9+9+12	6+6+9+12+12+24
	9+18+30	9+9+9+18	6+9+9+9+18	6+6+12+12+12+12
	9+18+36	9+9+9+24	6+9+9+9+24	6+6+12+12+12+18
	12+12+12	9+9+12+12	6+9+9+12+12	6+6+12+12+12+24
	12+12+18	9+9+12+18	6+9+9+12+18	6+9+9+9+9+9
	12+12+24	9+9+12+24	6+9+9+12+24	6+9+9+9+9+12
	12+12+30	9+9+18+18	6+9+9+18+18	6+9+9+9+9+18
	12+12+36	9+9+18+24	6+9+9+18+24	6+9+9+9+9+24
	12+18+18	9+12+12+12	6+9+12+12+12	6+9+9+9+12+12
	12+18+24	9+12+12+18	6+9+12+12+18	6+9+9+9+12+18
	12+18+30	9+12+12+24	6+9+12+12+24	6+9+9+9+12+24
	12+18+36	9+12+18+18	6+9+12+18+18	6+9+9+9+18+18
	18+18+18	9+12+18+24	6+9+12+18+24	6+9+9+12+12+12
		9+18+18+18	6+9+18+18+18	6+9+9+12+12+18
		12+12+12+12	6+12+12+12+12	6+9+9+12+12+24
		12+12+12+18	6+12+12+12+18	6+9+12+12+12+12
		12+12+12+24	6+12+12+12+24	6+9+12+12+12+18
		12+12+18+18	6+12+12+18+18	6+12+12+12+12+12
		12+12+18+24	6+12+12+18+24	6+12+12+12+12+18
		12+18+18+18	9+9+9+9+9	9+9+9+9+9+9
			9+9+9+9+12	9+9+9+9+9+12
			9+9+9+9+18	9+9+9+9+9+18
			9+9+9+9+24	9+9+9+9+9+24
			9+9+9+12+12	9+9+9+9+12+12
			9+9+9+12+18	9+9+9+9+12+18
			9+9+9+12+24	9+9+9+9+12+24
			9+9+9+18+18	9+9+9+12+12+12
			9+9+9+18+24	9+9+9+12+12+18
			9+9+12+12+12	9+9+12+12+12+12
			9+9+12+12+18	9+9+12+12+12+18
			9+9+12+12+24	9+12+12+12+12+12
			9+9+12+18+18	12+12+12+12+12+12
			9+9+12+18+24	
			9+9+18+18+18	
			9+12+12+12+12	
			9+12+12+12+18	
			9+12+12+12+24	
			9+12+12+18+18	
			12+12+12+12+12	
			12+12+12+12+18	
			12+12+12+12+24	
			12+12+12+18+18	
	6+24	6+6+18	6+6+6+6	6+6+6+6+6
	6+30	6+6+24	6+6+6+9	6+6+6+6+9
	6+36	6+6+30	6+6+6+12	6+6+6+6+12
	9+18	6+6+36	6+6+6+18	6+6+6+6+18
	9+24	6+9+9	6+6+6+24	6+6+6+6+24
	9+30	6+9+12	6+6+9+9	6+6+6+9+9
	9+36	6+9+18	6+6+9+12	6+6+6+9+12

CMZ3-62-6Z

When there One Way Cassette(T1W3) in the combination:
 Wall
 mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K;
 Cassette(TPA3&TIP3)/One Way
 Cassette(T1W3)/Ducted(CPA3)/Floor
 Ceiling(FPA3); 6K/9K/12K/18K/24K;
 Mid-static duct(CPA3H); 9K/12K(should be
 considered as 18K); 18K/24K(should be
 considered as 24K);

12+12	6+9+24	6+6+9+18	6+6+6+9+18	
12+18	6+9+30	6+6+9+24	6+6+6+9+24	
12+24	6+9+36	6+6+12+12	6+6+6+12+12	
12+30	6+12+12	6+6+12+18	6+6+6+12+18	
12+36	6+12+18	6+6+12+24	6+6+6+12+24	
18+18	6+12+24	6+6+18+18	6+6+6+18+18	
18+24	6+12+30	6+6+18+24	6+6+6+18+24	
18+30	6+12+36	6+9+9+9	6+6+9+9+9	
18+36	6+18+18	6+9+9+12	6+6+9+9+12	
24+24	6+18+24	6+9+9+18	6+6+9+9+18	
24+30	6+18+30	6+9+9+24	6+6+9+9+24	
24+36	6+18+36	6+9+12+12	6+6+9+12+12	
	9+9+9	6+9+12+18	6+6+9+12+18	
	9+9+12	6+9+12+24	6+6+9+12+24	
	9+9+18	6+9+18+18	6+6+9+18+18	
	9+9+24	6+9+18+24	6+6+9+18+24	
	9+9+30	6+12+12+12	6+6+12+12+12	
	9+9+36	6+12+12+18	6+6+12+12+18	
	9+12+12	6+12+12+24	6+6+12+12+24	
	9+12+18	6+12+18+18	6+6+12+18+18	
	9+12+24	6+12+18+24	6+6+12+18+24	
	9+12+30	6+18+18+18	6+6+18+18+18	
	9+12+36	6+18+18+24	6+6+18+18+24	
	9+18+18	9+9+9+9	6+9+9+9+9	
	9+18+24	9+9+9+12	6+9+9+9+12	
	9+18+30	9+9+9+18	6+9+9+9+18	
	9+18+36	9+9+9+24	6+9+9+9+24	
	12+12+12	9+9+12+12	6+9+9+12+12	
	12+12+18	9+9+12+18	6+9+9+12+18	
	12+12+24	9+9+12+24	6+9+9+12+24	
	12+12+30	9+9+18+18	6+9+9+18+18	
	12+12+36	9+9+18+24	6+9+9+18+24	
	12+18+18	9+12+12+12	6+9+12+12+12	
	12+18+24	9+12+12+18	6+9+12+12+18	
	12+18+30	9+12+12+24	6+9+12+12+24	
	12+18+36	9+12+18+18	6+9+12+18+18	
	18+18+18	9+12+18+24	6+9+12+18+24	
		9+18+18+18	6+9+18+18+18	
		12+12+12+12	6+12+12+12+12	
		12+12+12+18	6+12+12+12+18	
		12+12+12+24	6+12+12+12+24	
		12+12+18+18	6+12+12+18+18	
		12+12+18+24	6+12+12+18+24	
		12+18+18+18	9+9+9+9+9	
			9+9+9+9+12	
			9+9+9+9+18	
			9+9+9+9+24	
			9+9+9+12+12	
			9+9+9+12+18	
			9+9+9+12+24	
			9+9+9+18+18	
			9+9+9+18+24	
			9+9+12+12+12	
			9+9+12+12+18	
			9+9+12+12+24	
			9+9+12+18+18	
			9+9+12+18+24	
			9+9+18+18+18	
			9+12+12+12+12	
			9+12+12+12+18	
			9+12+12+12+24	
			9+12+12+18+18	
			12+12+12+12+12	
			12+12+12+12+18	
			12+12+12+12+24	
			12+12+12+18+18	
6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
6+30	6+6+30	6+6+9+18	6+6+6+12+18	6+6+6+9+9+18
6+36	6+6+36	6+6+9+24	6+6+6+12+24	6+9+9+9+9+18

	When there AHU in the combination: Wall mounted(CPP3(I)); 6K/9K/12K/18K/24K/30K/36K; Cassette(TPA3&TIP3)/One Way Cassette(T1W3)/Ducted(CPA3)/Floor Ceiling(FPA3); 6K/9K/12K/18K/24K; AHU; 18K/24K/30K/36K		9+18	6+9+18	6+6+12+18	6+9+9+9+18	9+9+9+9+9+18
			9+24	6+9+24	6+6+12+24	6+9+9+9+24	
			9+30	6+9+30	6+9+9+18	6+9+9+12+18	
			9+36	6+9+36	6+9+9+24	6+9+9+12+24	
			12+18	6+12+18	6+9+12+18	6+9+12+12+18	
			12+24	6+12+24	6+9+12+24	6+9+12+12+24	
			12+30	6+12+30	6+12+12+18	6+12+12+12+18	
			12+36	6+12+36	6+12+12+24	9+9+9+9+18	
			18+18	9+9+18	9+9+9+18	9+9+9+9+24	
			18+24	9+9+24	9+9+9+24	9+9+9+12+24	
			18+30	9+9+30	9+9+12+18	9+9+9+12+18	
			18+36	9+9+36	9+9+12+24	9+9+12+12+18	
			24+24	9+12+18	9+12+12+18	9+12+12+12+18	
			24+30	9+12+24	9+12+12+24		
			24+36	9+12+30	12+12+12+18		
				9+12+36	12+12+12+24		
				12+12+18			
				12+12+24			
				12+12+30			
			6+18	6+6+18	6+6+6+18	6+6+6+6+18	
			6+24	6+6+24	6+6+6+24	6+6+6+6+24	
			6+30	6+6+30	6+6+9+18	6+6+6+12+18	
			6+36	6+6+36	6+6+9+24	6+6+6+12+24	
			9+18	6+9+18	6+6+12+18	6+9+9+9+18	
			9+24	6+9+24	6+6+12+24	6+9+9+9+24	
			9+30	6+9+30	6+9+9+18	6+9+9+12+18	
			9+36	6+9+36	6+9+9+24	6+9+9+12+24	
			12+18	6+12+18	6+9+12+18	6+9+12+12+18	
			12+24	6+12+24	6+9+12+24	6+9+12+12+24	
			12+30	6+12+30	6+12+12+18	6+12+12+12+18	
			12+36	6+12+36	6+12+12+24	9+9+9+9+18	
			18+18	9+9+18	9+9+9+18	9+9+9+9+24	
			18+24	9+9+24	9+9+9+24	9+9+9+12+24	
			18+30	9+9+30	9+9+12+18	9+9+9+12+18	
			18+36	9+9+36	9+9+12+24	9+9+12+12+18	
			24+24	9+12+18	9+12+12+18	9+12+12+12+18	
			24+30	9+12+24	9+12+12+24		
			24+36	9+12+30	12+12+12+18		
				9+12+36	12+12+12+24		
				12+12+18			
				12+12+24			
				12+12+30			
			9+9	9+9+9	9+9+9+9	9+9+9+9+9	
			9+12	9+9+12	9+9+9+12	9+9+9+9+12	
			9+18	9+9+18	9+9+9+18	9+9+9+12+12	
			9+24	9+9+24	9+9+9+24	9+9+12+12+12	
			12+12	9+12+12	9+9+12+12	9+12+12+12+12	
			12+18	9+12+18	9+9+12+18	12+12+12+12+12	
			12+24	9+12+24	9+9+12+24		
			18+18	12+12+12	9+12+12+12		
			18+24	12+12+18	9+12+12+18		
			24+24	12+12+24	9+12+12+24		
					12+12+12+12		
					12+12+12+18		
					12+12+12+24		

Key Considerations for Indoor and Outdoor Unit Load Management

When the total load of indoor units surpasses the nominal capacity of the outdoor unit, the effective output capacity of each indoor unit will be reduced accordingly. This is particularly noticeable during heating mode.

If the indoor units are of equal size, smaller indoor units can be combined with units of the same size. (For instance, since the sizes of the 9K and 12K units are identical, the 12K unit can be treated as a 9K unit and used in conjunction with multiple 9K units.)

For optimal efficiency, a 12K unit should be regarded as an 18K unit in the combination chart, as it shares the same size as a standard 18K unit.

Regarding the AHU series:

a. The AHU fan will either stop (when in "follow me On" mode) or run intermittently (when in "follow me Off" mode) upon reaching the set temperature.

b. When linked to a third-party thermostat via a 24V connection, if there is no heating demand from the AHU, the fan ON command from the thermostat will be ineffective, and the fan will not activate.

c. The system will begin to operate when the AHU detects an emergency heating demand.